

The manufacturer is granted the following type test approval mark in virtue of a test report:

Category test approval mark:	safety valve
Technical inspection and surveillance organisation and test report:	TÜV NORD dated 1992-03-02 and 13th supplement dated 2022-09-23
Manufacturer/Circulator:	HEROSE GmbH Armaturen und Metalle Elly-Heuss-Knapp-Straße 12 23843 Bad Oldesloe GERMANY
Type test approval mark:	TÜV . SV . 22 - 780 . A₀ . S/G . α_w . p
Design:	direct acting angle type safety valve, spring loaded
Type:	06381, 06383, 06388, 06430 cap 06413, 06418, 06435 lifting device 06386, 06387 cap 06416, 06417 lifting device 06382, 06389 cap 06419 lifting device
The adjudication is made pursuant to:	<ul style="list-style-type: none">- VdTÜV-Merkblatt Sicherheitsventil 100, edition 2017-04-13, in conjunction with VdTÜV-Merkblatt General 002, edition 2021-05-08- essential safety requirements of Directive 2014/68/EU from 15.05.2014 (Pressure Equipment Directive)- AD 2000-Merkblatt A 2, edition 2020-01- AD 2000-Merkblatt A 4, edition 2015-11- DIN EN ISO 4126-1:2016-12
Valid until:	2027-10-31

The adjudication is revocable. The previous certificate is replaced herewith.

Note: The manufacturer or importer is obliged to the competent Authorized Inspector to conduct a random check on the accessories concerning identity to the type once a year. The accessories have to be taken from the current production.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

division industry and plant engineering

www.tuev-verband.de/en