

06388/06418/06383/06413.100 [Safety Relief Valve] 06388/06418/06383/06413.1004/1006
 4/1006 [91088]
 Capacity Tests: Sec. VIII Div. 1 at unknown lab on July 30, 1999
 Method of Establishing Relieving Capacity: Flow Capacity, Slope
 Certified Value: 1.517 SCFM/PSIA
 Media - Test: Air/Gas; Certified: Air, Gas
 Set Pressure Definition: Initial Audible Discharge
 Blowdown Characteristics: Fixed
 Designed by: HEROSE GMBH Armaturen Und Metalle {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
0.5-0.75 NPS	1 NPS	86,6	10.5 mm	2.2 mm	42-725 psi	Air	VIII Div. 1

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE GMBH Armaturen Und Metalle (HEG) Bad Oldesloe, 23843 Germany	VIII Div. 1	12.09.2026