

06002/06012 gas tight [91246] [Safety Relief Valve] 06002/06012 gas tight  
 Capacity Tests: Sec. VIII Div. 1 at National Board Testing Lab on April 9, 2015  
 Method of Establishing Relieving Capacity: Flow Capacity, Slope  
 Certified Value: 0.302 SCFM/PSIA  
 Media - Test: Air/Gas; Certified: Air, Gas  
 Set Pressure Definition: Initial Audible Discharge  
 Blowdown Characteristics: Fixed  
 Designed by: HEROSE GMBH Armaturen Und Metalle {HEG}

Inlet Size	Outlet Size	Flow Area	Orifice [designator] dia.	Lift	Set Pressure Range	Media	Code Section
0.25-0.5 NPS	.375 NPS	28,3	6 mm	0.8 mm	74-798 psi	Air	VIII Div. 1

Manufacturer/Assembler	Code Sections	Expiration Date
HEROSE GMBH Armaturen Und Metalle (HEG) Bad Oldesloe, 23843 Germany	VIII Div. 1	05.27.2027