



THE NATIONAL BOARD
OF BOILER AND PRESSURE VESSEL INSPECTORS

January 12, 2016

Marc Zaubitzer
Herose Gmbh Armaturen Und Metalle
Elly-Heuss-Knapp-Strasse 12
Bad Oldesloe, 23843
GERMANY

**Subject: Capacity Certification, Valve Type: 06420/06421/06425/06426/06440/06441/
06445/06446.1810/.1812 (18 mm orifice)
NB Cap Cert. No.: HEG-M91280**

Dear Mr. Zaubitzer:

We have reviewed the test results referenced below which were performed at the **National Board Testing Laboratory** on January 7, 2016 for the purpose of testing for capacity certification of the subject valve type as required by paragraph UG-136(c)(3) of Section VIII of the ASME Code.

Herose Gmbh Armaturen Und Metalle is hereby granted capacity certification and authorization to apply the “NB” mark and ASME Certification mark with “UV” designators to the valve type listed in the scope of certification. This authorization is valid only for the above location and only while the organization is fully implementing its quality control system as accepted by the National Board.

SCOPE OF CERTIFICATION

**Valve Type: 06420/06421/06425/06426/06440/06441/06445/
06446.1810/.1812 (18 mm orifice)**

Organization Type: Manufacturer

Certified Rating Value/Sizes/Pressure Ranges: As listed in the NB-18

Certification Expiration Date: January 7, 2022

Sincerely,

Richard J. Bulgin
Senior Staff Engineer, Pressure Relief Dept.

REFERENCING TEST NUMBERS: 41284A, 41286A

File: AC: 160112 HEG-M91280 Pass